
CONFIDENTIAL AND PROPRIETARY PROPER
EBDQ - NC, PLLC
MAY NOT BE USED FOR CONSTRUCTION OR PRO
ANY THIRD PARTIES WINDLUT PRIOR WRITTEN C

• 2017 ELLIOTT BAY DESIGN GROUP.

SERVICE

SERVICE	F	PIPING	MATERIAL S			CHEDULE VALVES		FITTINGS	FLEX CONNECTIONS	REMARKS
	SIZE MATERIAL		MATERIAL GASKETS		BOLTING	BODY	TRIM	1		
FIREMAIN MAWP: 120 PSIG MAX TEMP: AMBIENT	2 ½" & ABOVE	CU-NI 90/10 ASTM B466 SEAMLESS CLASS 200	FLANGE: CU-NI 90/10 OR BRONZE ASTM B369 ANSI B16.5 SLIP-ON OR WELD NECK, 150#	INORGANIC FIBER WITH NITRILE BINDER ABS FIRE—SAFE TYPE APPROVED	BOLTS: STAINLESS STEEL ASTM A193 GRADE B8M ANSI B18.2.1 NUTS: STAINLESS STEEL ASTM A194 GRADE 8M ANSI B18.2.2	BUTTERFLY: BRONZE OR LINED DUCTILE IRON, WAFER TYPE  CHECK: BRONZE, ASTM B61 OR B62, 150#, FLANGED  SEE NOTES 10 & 13	BUTTERFLY: BRONZE TRIM, RENEWABLE DISK CHECK: BRONZE DISK, RENEWABLE SEATS & SEALS	CU-NI 90/10 OR BRONZE ASTM B61 OR B62, BUTT WELD	-	-
	2" & BELOW		CU-NI 90/10 UNION, SOCKET WELD, ASTM B369, 150#	-	-	BALL: BRONZE ASTM B61 OR B62, THREADED	BALL: CHROME PLATED BRONZE BALL PTFE SEATS	CU-NI 90/10 UNION, SOCKET WELD	-	
SHELL CONNECTIONS MAWP: 120 PSIG MAX TEMP: AMBIENT	ALL	A106, GR B, ANSI B36.10	FLANGE CARBON STEEL ASTM A105 ANSI B16.5 SLIP-ON OR WELD NECK, 150#	INORGANIC FIBER WITH NITRILE BINDER ABS FIRE—SAFE TYPE APPROVED	BOLTS: STAINLESS STEEL ASTM A193 GRADE B8M ANSI B18.2.1 NUTS: STAINLESS STEEL ASTM A194 GRADE 8M ANSI B18.2.2	GATE: DUCTILE IRON ASTM A395 OR CARBON STEEL ASTM A216 FLANGED, 150#	GATE: STAINLESS STEEL RENEWABLE DISC AND SEAT ASTM A182	CARBON STEEL ASTM A234, GR WPB ANSI B16.9 BUTT WELD SCH 80	-	

E Q U I P M E N T L I S T									
QTY.	SERVICE	TYPE	MODEL	CAPACITY	DRIVE	REMARKS			
2	SEA WATER STRAINER 3" NPS	DUPLEX BASKET TYPE	1	-	-	SS BASKET BRONZE BODY			
2	FIRE PUMP	HORIZONTAL CENTRIFUGAL	-	170 GPM © 243' TDH	208v/3¢/60Hz 25 HP TEFC MOTOR 3550 RPM	SS 316 BODY			



## DETAIL 1—6B TYP FIRE STATION SEE NOTE 11 VENT TO OVERHEAD OF SPACE CUNI STEEL COMPRESSED AIR BLOWDOWN SEE 2-3B AND REF 2 COMPRESSED AIR BLOWDOWN SEE REF 3. 14" SCH XS STEEL PIPE IN VOID B 16" MIN 3/8" STAINLESS STEEL STRAINER PLATE HINGED WITH 316 SS PINS AND FASTENERS

DETAIL 1-5A SEA CHESTS

SYMBOLS LIST								
-	DIRECTION OF FLOW ARROW							
<b>~</b> —	MATERIAL TRANSITION							
⊳	REDUCER							
-	DECK/BHD PENETRATION							
M	GATE VALVE							
M	BALL VALVE							
ightharpoonup	SWING CHECK VALVE							
$\bowtie$	BUTTERFLY VALVE							
H)	CENTRIFUGAL PUMP							
<b>→</b> ∞ <b>-</b> ⊘ P	PRESSURE GAUGE							
<b>→</b> ✓  ﴿	VACUUM PRESSURE GAUGE							
₽Ţ	PRESSURE TRANSDUCER							
-4	OVERBOARD DISCHARGE							
	FIRE STATION							
⊗⊗	DUPLEX STRAINER							
∆ <sup>‡</sup>	ANGLED GLOBE HOSE VALVE							
×	STOP CHECK VALVE							
$\forall$	SEA CHEST							
Ð	BILGE ROSEBOX SUCTION							
$\overline{A}$	GATE VALVE WITH REACH ROD							
中	DRAIN PLUG							
N.S. / N.O.	NORMALLY SHUT / NORMALLY OPEN							

0 4 4 5 0 1 0 1 1 0 7

GENERAL NOTES (CONT)

11. FIRE STATIONS SHALL HAVE A 1-1/2" HOSE VALVE, AND BE FITTED WITH 50 FEET OF 1-1/2" LINED COMMERCIAL FIRE HOSE CONFORMING TO UL19, HOSE WRENCH, AND A USCG APPROVED COMBINATION FIRE NOZZLE WITH 5/8" ORIFICE. HOSES SHALL BE CONNECTED AND STOWED IN APPROVED ENCLOSED HOSE RACKS.

12. NOTED VALVES ISOLATE EXTERIOR FIRE STATIONS PERIODICALLY EXPOSED TO FREEZING TEMPERATURES. LOCATE EACH VALVE IN AN EASILY ACCESSIBLE LOCATION AS CLOSE AS POSSIBLE TO THE WEATHER BOUNDARY. WHERE LOCATED BEHIND JOINERY, PROVIDE A HINGED ACCESS PLATE.

13. BUTTERFLY VALVES IN THE FIRE SYSTEM SHALL HAVE PASSED A FIRE TEST SUCH AS API 607. THE CONTRACTOR SHALL SUBMIT DOCUMENTATION.

14. APPROVED MECHANICAL FITTING SYSTEMS MAY BE SUBSTITUTED FOR WELDED FITTINGS. FITTINGS SHALL BE ABS AND USCG APPROVED, AND USED IN ACCORDANCE WITH REGULATORY REQUIREMENTS AND MANUFACTURER'S RECOMMENDATIONS.

15. MATERIAL TRANSITIONS FROM STEEL TO COPPER NICKEL PIPE SHALL BE ACCOMPLISHED VIA FLANGED JOINTS. THE JOINTS SHALL BE FITTED WITH GALVANIC ISOLATION KITS TO PREVENT DIRECT METAL TO METAL CONTACT.

16. FIRE STATIONS SHALL BE EQUIPPED WITH PUSH BUTTONS AND RUNNING LIGHTS FOR REMOTE START OF FIRE PUMP NO. 1. FIRE PUMP NO. 2 SHALL BE CAPABLE OF REMOTE START FROM THE EOS AND THE PILOTHOUSE. THE PILOTHOUSE SHALL HAVE RUNNING LIGHTS AND PRESSURE GAUGES FOR BOTH PUMPS. SEE REF 1.

17. WELDED FITTINGS SHALL BE TIG WELDED. SIL-BRAZING IS NOT

18. WHERE PIPING PENETRATES BULKHEADS OR DECKS, WELDED SLEEVES OR PENETRATION SLEEVES WITH SLIPSIL SEALING PLUGS (ABS CERT NO. 06—LD182012B/1—PDA) OR RISE/NOFIRNO SEALING (ABS CERT NO 09—LD398300B/1—PDA) MAY BE USED. INSTALL PIPING TRANSITS IN ACCORDANCE WITH REGULATORY REQUIREMENTS AND MANUFACTURER'S APPROVED INSTALLATION DETAILS.

19. LOCATE DRAIN VALVES FOR COMPLETE DRAINAGE OF EXTERIOR FIRE STATIONS.

20. "A" END HOSE STATIONS SHALL BE EQUIPPED WITH ATFF HOSE ENDS WITH (2) FIVE GALLON CONTAINERS IN ENGINE ROOMS.

 CONTRACTOR SHALL INSTALL PUMPS SUCH THAT FLOODED SUCTIONS ARE MAINTAINED AT OPERATIONAL LIGHTSHIP DRAFT.

REV ZONE DESCRIPTION H I S T O R Y

REV ZONE L DESCRIPTION U DATE APVD
A 1-3C 1. ADDED NOTE 21. U LGB 8/30/17 LGB

## GENERAL NOTES

- VESSEL TO BE CONSTRUCTED IN ACCORDANCE WITH 46 CFR SUBCHAPTER H REGULATIONS.
- 2. THIS DRAWING IS DIAGRAMMATIC AND DOES NOT REPRESENT A COMPLETE DETAILED DESIGN. EQUIPMENT LAYOUT IN A GIVEN AREA IS APPROXIMATE. THE CONTRACTOR SHALL DEVELOP A DETAILED DESIGN THAT PROVIDES A FULLY FUNCTIONAL ARRANGEMENT SUITABLE FOR INSTALLATION, TAKING INTO ACCOUNT ALL NECESSARY SYSTEM INTERFACES AND INTERFERENCES. DIMENSIONS SHALL BE VERIFIED FROM THE SHIP AND MANUFACTURER'S CERTIFIED DRAWINGS AS APPROPRIATE.
- PIPING SHALL BE RUN AS DIRECTLY AS PRACTICABLE WITH A MINIMUM NUMBER OF BENDS AND FITTINGS. PIPE SPOOLS SHALL BE SIZED AND ARRANGED TO PROVIDE FOR REMOVAL, INSPECTION, SERVICING, AND REPLACEMENT OF PIPING, VALVES, FITTINGS, AND EQUIPMENT WITHOUT CUTTING STRUCTURE OR PIPING.
- AVOID POCKETS IN THE PIPE LINES. BOSSES AND VALVES OR SCREWED PLUGS SHALL BE FITTED TO ENABLE COMPLETE DRAINING OF PIPES WHERE POCKETS DO OCCUR.
- PIPING SHALL BE ADEQUATELY SUPPORTED BY HANGERS IN ACCORDANCE WITH ASTM F708. HANGERS SHALL BE ATTACHED TO THE PIPE WITH BOLTED CLAMPS AND WELDED TO BASIC SHIP STRUCTURE. HANGERS SHALL NOT BE WELDED DIRECTLY TO PIPES, ALL COPPER-NICKEL PIPING SHALL BE SUPPORTED USING INSULATED HANGERS.
- 6. THE PIPING SYSTEM SHALL BE CLEANED AND TESTED IN ACCORDANCE WITH USCG REQUIREMENTS. SEE REF 1.
- 7. VALVES LOCATED BELOW THE FLOOR PLATES SHALL BE PROVIDED WITH REACH RODS. ALL VALVES SHALL BE PROVIDED WITH VISUAL POSITION INDICATION.
- S. OVERBOARD SHELL PENETRATIONS SHALL BE LOCATED AS FAR ABOVE BASELINE AS POSSIBLE WHILE STILL BEING UNDER THE GUARDS.
- TOTAL DYNAMIC HEAD OF PUMPS FOR REQUIRED FLOW ARE APPROXIMATE ONLY. THE CONTRACTOR SHALL PROVIDE PUMPS MEETING THE REQUIRED FLOW WITH THE INSTALLED PIPING SYSTEM. PUMP MOTORS SHALL BE SELECTED TO PREVENT MOTOR OVERLOAD OVER THE ENTIRE PUMP OPFRATING RANGE.
- 10. FIRE STATION HOSE VALVES MAY BE COMMERCIAL SCREWED FIRE HOSE VALVES IN LIEU OF FLANGED.

## REFERENCES

1. 16101-200-832-1 TECHNICAL SPECIFICATION

2. 16101-200-529-1 BILGE AND BALLAST SCHEMATIC

3. 16101-200-551-1 COMPRESSED AIR PIPING SCHEMATIC



FILIOH Rav

## Elliott Bay Design Group North Carolina, PLLC

NORTH CAROLINA D.O.T.
RALEIGH, NORTH CAROLINA

NEW RIVER CLASS FERRY

FIRE MAIN SYSTEM SCHEMATIC

size D	DWG N	16101-200-521-1									A
SCALE NONE			FILE NAME 16101-200-521-1A					SHEET	1	OF	2
DWN MWR MOD			CKD NJB		APVD LGB	APVD	APVD DATE 7/21/		17		

5 4 🕈 3

